

www.visy.com.au

Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2023/24 Reporting Period.

Site: Visy Paper Pty Ltd, Smithfield NSW Licence No: 4100

Date of Test: 15 May 2024 **Tester:** Ektimo Pty Ltd

Report No: R016962 Report Date: 20 June 2024

Table 1: Summary of Average Emission Test Results (Report No. R012785)

Pollutant	Unit of measure	Concentration limit	Result	Compliance
Nitrogen dioxide	mg/m³	250*	<2	Yes
Nitric oxide	mg/m³	250*	99	Yes
Oxygen	%	N/A	4.5	N/A
Temperature	°C	N/A	182	N/A
Velocity	m/s	N/A	12	N/A
Volumetric flow rate	m³/s	N/A	35	N/A
Dry gas density	kg/m³	N/A	1.33	N/A
Moisture	%	N/A	15	N/A
Molecular weight stack gases	g/gmol	N/A	29.7	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by: Date: 17/10/2024

Ben Casauria

Visy National Environment Manager

DAPER & PAPER