

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity					
Period: 6 Minutes		Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
01/03/25 11:18	01/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.22
02/03/25 11:18	02/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.67
03/03/25 11:18	03/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.75
04/03/25 11:18	04/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.82
05/03/25 11:18	05/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.52
06/03/25 11:18	06/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.54
07/03/25 11:18	07/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.68
08/03/25 11:18	08/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.65
09/03/25 11:18	09/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.60
10/03/25 11:18	10/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.23
11/03/25 11:18	11/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.14
12/03/25 11:18	12/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.69
13/03/25 11:18	13/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.74
14/03/25 11:18	14/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.17
15/03/25 11:18	15/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.72
16/03/25 11:18	16/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.95
17/03/25 11:18	17/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.78
18/03/25 11:18	18/03/25 11:24	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.40


24/03/25 11:12	24/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.59
25/03/25 11:12	25/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.60
26/03/25 11:12	26/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.35
27/03/25 09:00	27/03/25 09:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	30.35
27/03/25 11:12	27/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.58
28/03/25 11:12	28/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.63
29/03/25 11:12	29/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.56
30/03/25 11:12	30/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.36
31/03/25 11:12	31/03/25 11:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.15

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager



R. DIPANJAND
ON BEHALF OF