

Visy Pulp and Paper Tumut CEMS - Correction Log

20/07/2025

Reporting Period:

1/06/2025 - 1/07/2025

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1

Monitoring Type: Continuous

Sample Type: Air

Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %		
Start Time	End Time	Cause	Operational State	Explanation	Max Reading
05/06/25 09:54	05/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.62
06/06/25 09:54	06/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.97
07/06/25 09:54	07/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.96
08/06/25 09:54	08/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.06
09/06/25 09:54	09/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.23
10/06/25 09:54	10/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.95
10/06/25 16:42	10/06/25 16:48	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.38
11/06/25 09:54	11/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.22
12/06/25 09:54	12/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.77
12/06/25 10:30	12/06/25 10:36	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	21.18
13/06/25 09:54	13/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.20
14/06/25 09:54	14/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.94
15/06/25 09:54	15/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.44
16/06/25 07:00	16/06/25 07:06	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.22
16/06/25 09:54	16/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.79
17/06/25 09:54	17/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.95
18/06/25 09:54	18/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.87
19/06/25 09:54	19/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	29.11

19/06/25 19:18	19/06/25 19:24	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	21.53
19/06/25 23:30	19/06/25 23:36	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.84
20/06/25 09:54	20/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.76
21/06/25 09:54	21/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	27.98
22/06/25 01:54	22/06/25 02:00	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	21.12
22/06/25 09:54	22/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	26.62
23/06/25 09:54	23/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.75
23/06/25 23:06	23/06/25 23:12	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.86
23/06/25 23:18	23/06/25 23:24	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.12
24/06/25 01:12	24/06/25 01:18	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	25.87
24/06/25 04:54	24/06/25 05:00	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.05
24/06/25 05:00	24/06/25 05:06	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	21.12
24/06/25 05:12	24/06/25 05:18	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.34
24/06/25 09:54	24/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	25.68
24/06/25 13:54	24/06/25 14:06	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	24.28
25/06/25 01:54	25/06/25 02:00	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.22
25/06/25 03:06	25/06/25 03:18	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	27.80
25/06/25 07:42	25/06/25 07:54	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	27.97
25/06/25 08:00	25/06/25 08:06	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	23.75
25/06/25 09:54	25/06/25 10:00	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.99
25/06/25 10:12	25/06/25 11:36	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	29.06
25/06/25 14:36	25/06/25 14:42	Instrument Error	Equipment Issue/Failure	Main Stack opacity false high readings, drifting upwards.	20.92
26/06/25 13:42	26/06/25 13:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.83
27/06/25 13:48	27/06/25 13:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.14
28/06/25 13:48	28/06/25 13:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.88
29/06/25 13:48	29/06/25 13:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.40
30/06/25 13:48	30/06/25 13:54	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.22

Authorised By:

Uday Bhagwat
Pulp Mill Manager


J. Olivier

Johan Stoltz
General Manager

