



Visy Pulp and Paper Tumut CEMS - Correction Log

8/04/2026

Reporting Period: 1/03/2026 - 1/04/2026 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

Opacity						Period: 6 Minutes	Limit: 20.00 %
Start Time	End Time	Cause	Operational State	Explanation	Max Reading		
01/03/26 10:12	01/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.38		
02/03/26 10:12	02/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.51		
03/03/26 10:12	03/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.61		
04/03/26 10:12	04/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.80		
05/03/26 10:12	05/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.02		
06/03/26 10:12	06/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.74		
07/03/26 10:12	07/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.88		
08/03/26 10:12	08/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.08		
09/03/26 10:12	09/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.12		
10/03/26 10:12	10/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.82		
11/03/26 10:12	11/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.86		
12/03/26 09:00	12/03/26 09:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	36.39		
12/03/26 10:12	12/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.09		
13/03/26 10:12	13/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.15		
14/03/26 10:12	14/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.11		
15/03/26 10:12	15/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.13		
16/03/26 10:12	16/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.52		
17/03/26 10:12	17/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.77		

18/03/26 10:12	18/03/26 10:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.33
24/03/26 09:12	24/03/26 09:54	Instrument Error	Equipment Issue/Failure	Gas Generator failed tripping the Kiln repairs carried out, and Plant was started and stabilized.	43.41
25/03/26 06:48	25/03/26 06:54	Instrument Error	Equipment Issue/Failure	Gas Generator failed tripping the Kiln.	35.57
25/03/26 10:06	25/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.33
26/03/26 10:06	26/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.56
27/03/26 10:06	27/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.39
28/03/26 10:06	28/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.73
29/03/26 10:06	29/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.52
30/03/26 10:06	30/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.95
31/03/26 10:06	31/03/26 10:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.14

Authorised By:

Uday Bhagwat
Pulp Mill Manager



Johan Stoltz
General Manager

