



Visy Pulp and Paper Tumut CEMS - Correction Log

5/05/2026

Reporting Period:

1/04/2026 - 1/05/2026

Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
 Monitoring Type: Continuous
 Sample Type: Air
 Description: Exit point from Stack 1 to atmosphere

| Opacity | | Period: 6 Minutes | Limit: 20.00 % | | | |
|----------------|----------------|-----------------------------|-----------------------|------------------|-------------|--|
| Start Time | End Time | Cause | Operational State | Explanation | Max Reading | |
| 01/04/26 10:06 | 01/04/26 10:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.21 | |
| 01/04/26 11:36 | 01/04/26 11:42 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.98 | |
| 02/04/26 10:06 | 02/04/26 10:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.06 | |
| 03/04/26 10:06 | 03/04/26 10:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.30 | |
| 04/04/26 10:06 | 04/04/26 10:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.01 | |
| 05/04/26 09:06 | 05/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.68 | |
| 06/04/26 09:06 | 06/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.91 | |
| 07/04/26 09:06 | 07/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 22.48 | |
| 08/04/26 09:06 | 08/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.86 | |
| 09/04/26 09:06 | 09/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.95 | |
| 10/04/26 09:06 | 10/04/26 09:12 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 22.99 | |
| 18/04/26 09:00 | 18/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.24 | |
| 19/04/26 09:00 | 19/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.05 | |
| 20/04/26 09:00 | 20/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.32 | |
| 21/04/26 09:00 | 21/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.69 | |
| 22/04/26 09:00 | 22/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.60 | |
| 23/04/26 09:00 | 23/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.83 | |
| 24/04/26 09:00 | 24/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.77 | |

| | | | | | |
|----------------|----------------|-----------------------------|-----------------------|------------------|-------|
| 25/04/26 09:00 | 25/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.89 |
| 26/04/26 09:00 | 26/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 20.91 |
| 27/04/26 09:00 | 27/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.43 |
| 28/04/26 09:00 | 28/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.98 |
| 29/04/26 09:00 | 29/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.22 |
| 30/04/26 09:00 | 30/04/26 09:06 | Auto Zero Span Verification | Normal (Steady State) | Auto Calibration | 21.25 |

Authorised By:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager


