1302 Snowy Mountains Highway, Tumut, NSW 2720 Australia
Phone +61 2 6947 7900 Facsimile +61 2 6947 5315
Visy Paper Pty Ltd ACN 005 803 234 ABN 49 984 541 896
Visy Pulp and Paper Pty Ltd ABN 30 086 513 144
www.visy.com.au

Air Monitoring Data Report

14-Oct-26

The attached report contains the air monitoring data for all the licenced air monitoring points as required by the Environment Protection Licence 10232, for July 2026 to September 2026 as part of the reporting period July 2026 - June 2027.

Authorised by:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager

VP9-10-10.5-FM-001 **Summary of Continuous Emissions Monitoring Data - Stack 1**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 1

Environment Protection Licence: 10232

Description: Exit point from Stack 1 to atmosphere

Reporting Period: July 2026 to June 2027

Monitoring Type: Continuous

Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Concentration Limit	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Flow	Nm3/s	100	100.00	71.29	88.64	80.54	Y	
		Hydrogen chloride	mg/m3	50	100.00	0.00	21.11	1.28	Y	
		Moisture	%	N/A	100.00	0.00	28.03	24.81	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	136.02	277.70	220.43	Y	
		Opacity	%	20	99.66	0.00	48.42	2.93	N	Equipment Issues
		Oxygen (O2)	%	N/A	100.00	0.65	6.01	3.27	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.00	34.36	4.76	Y	
		Temperature	°C	N/A	100.00	134.46	231.08	184.87	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.09	4.21	0.16	Y	Planned Maintenance
August	14-Sep	Flow	Nm3/s	100	100.00	42.55	87.78	80.74	Y	
		Hydrogen chloride	mg/m3	50	100.00	0.00	27.50	0.74	Y	
		Moisture	%	N/A	100.00	0.00	28.18	24.81	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	163.21	297.00	223.84	Y	
		Opacity	%	20	99.65	0.09	19.67	2.78	Y	
		Oxygen (O2)	%	N/A	100.00	1.97	10.69	3.48	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.00	368.54	32.59	Y	Planned Maintenance
		Temperature	°C	N/A	100.00	144.43	229.12	185.25	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.05	0.23	0.15	Y	
September	14-Oct	Flow	Nm3/s	100	100.00	45.69	98.55	78.81	Y	
		Hydrogen chloride	mg/m3	50	99.86	0.00	10.57	1.11	Y	
		Moisture	%	N/A	100.00	0.00	28.70	24.47	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	152.73	378.57	219.18	Y	
		Opacity	%	20	99.71	0.00	33.61	2.76	N	Equipment Issues
		Oxygen (O2)	%	N/A	100.00	2.14	22.36	3.54	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.00	140.07	27.78	Y	
		Temperature	°C	N/A	100.00	138.30	220.64	183.26	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.10	0.80	0.17	Y	

VP9-10-10.5-FM-002 **Summary of Periodic Stack Testing - Stack 1**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 1 **Environment Protection Licence:** 10232

Description: Exit point from Stack 1 to Atmosphere **Reporting Period:** July 2026 to June 2027

Monitoring Type: Grab Sample **Sample Type:** Air

Pollutant	Unit of measure	Concentration Limit	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Compliance (Yes/No)	Comment
Chlorine	mg/m3	100	Annual						
Sulfuric acid mist & sulfur trioxide (as SO3)	mg/m3	20	Annual						
TCDD (equivalent)	ng/m3	0.1	Annual						
Total Solid Particles	mg/m3	50	1st Qrt	5-Aug-26	01-Sep-26	R020818	30	Y	
Total Solid Particles	mg/m3	50	2nd Qrt						
Total Solid Particles	mg/m3	50	3rd Qrt						
Total Solid Particles	mg/m3	50	4th Qrt						
Type 1 and 2 substances	mg/m3	1	Annual						

ND- No Data
N/A- Not Applicable

VP9-10-10.5-FM-003 Summary of Continuous Emissions Monitoring Data - Recovery Boiler A

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 2

Environment Protection Licence: 10232

Description: Discharge duct downstream of Recovery Boiler A prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Continuous

Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Reporting Level	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Carbon monoxide (CO)	mg/m3	N/A	100.00	0.55	1133.28	79.65	N/A	
		Flow	Nm3/s	N/A	100.00	0.05	96.99	51.25	N/A	
		Moisture	%	N/A	100.00	0.00	26.71	24.47	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	91.69	234.20	157.26	N/A	
		Opacity	%	N/A	100.00	0.77	22.57	2.94	N/A	
		Oxygen (O2)	%	N/A	100.00	1.27	6.91	3.73	N/A	
		Temperature	°C	N/A	100.00	167.44	182.84	174.09	N/A	
August	14-Sep	Carbon monoxide (CO)	mg/m3	N/A	100.00	1.16	660.08	76.35	N/A	
		Flow	Nm3/s	N/A	100.00	0.00	96.25	46.10	N/A	
		Moisture	%	N/A	100.00	0.00	27.29	24.30	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	50.29	222.95	159.91	N/A	
		Opacity	%	N/A	100.00	0.41	29.75	2.56	N/A	
		Oxygen (O2)	%	N/A	100.00	1.49	20.78	3.93	N/A	
		Temperature	°C	N/A	100.00	148.32	183.58	174.39	N/A	
September	14-Oct	Carbon monoxide (CO)	mg/m3	N/A	100.00	2.90	544.10	74.57	N/A	
		Flow	Nm3/s	N/A	100.00	0.00	138.14	47.15	N/A	
		Moisture	%	N/A	100.00	0.00	42.05	25.01	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	0.94	245.01	186.73	N/A	
		Opacity	%	N/A	100.00	0.20	23.72	2.24	N/A	
		Oxygen (O2)	%	N/A	100.00	2.19	22.38	3.65	N/A	
		Temperature	°C	N/A	100.00	168.97	180.92	173.74	N/A	

VP9-10-10.5-FM-004 **Summary of Periodic Stack Testing - Recovery Boiler A**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 2

Environment Protection Licence: 10232

Description: Discharge duct downstream of Recovery Boiler A prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Grab Sample

Sample Type: Air

Pollutant	Unit of measure	Reporting Level	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Compliance(Yes/No)	Comment
Methanol	mg/m3	N/A	Annual						
Total Solid Particles	mg/m3	N/A	Annual						

ND - No Data
N/A - Not applicable

VP9-10-10.5-FM-005 **Summary of Continuous Emissions Monitoring Data - Power Boiler**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 3

Environment Protection Licence: 10232

Description: Discharge duct downstream of Power Boiler prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Continuous

Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Reporting Level	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Carbon monoxide (CO)	mg/m3	N/A	100.00	4.70	136.09	18.79	N/A	
		Flow	Nm3/s	N/A	100.00	0.03	72.68	36.40	N/A	
		Moisture	%	N/A	100.00	0.00	31.13	22.66	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	50.75	250.80	179.69	N/A	
		Opacity	%	N/A	100.00	2.81	33.88	9.30	N/A	
		Oxygen (O2)	%	N/A	100.00	0.13	9.06	4.08	N/A	
		Temperature	°C	N/A	100.00	192.27	210.10	200.70	N/A	
August	14-Sep	Carbon monoxide (CO)	mg/m3	N/A	100.00	3.38	174.44	16.79	N/A	
		Flow	Nm3/s	N/A	100.00	0.03	74.39	36.30	N/A	
		Moisture	%	N/A	100.00	0.00	31.66	22.65	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	53.48	262.10	187.62	N/A	
		Opacity	%	N/A	100.00	3.23	30.23	9.12	N/A	
		Oxygen (O2)	%	N/A	100.00	1.62	7.46	3.88	N/A	
		Temperature	°C	N/A	100.00	192.27	211.33	201.25	N/A	
September	14-Oct	Carbon monoxide (CO)	mg/m3	N/A	100.00	6.10	164.96	20.78	N/A	
		Flow	Nm3/s	N/A	100.00	0.04	75.55	34.52	N/A	
		Moisture	%	N/A	100.00	0.00	30.30	20.94	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	69.82	256.99	182.16	N/A	
		Opacity	%	N/A	100.00	3.32	30.28	9.10	N/A	
		Oxygen (O2)	%	N/A	100.00	2.23	7.32	3.86	N/A	
		Temperature	°C	N/A	100.00	186.60	207.56	197.83	N/A	

VP9-10-10.5-FM-006 **Summary of Periodic Stack Testing - Power Boiler**

VISY FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 3

Environment Protection Licence: 10232

Description: Discharge duct downstream of Power Boiler prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Grab Sample

Sample Type: Air

Pollutant	Unit of measure	Concentration Limit	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Compliance (Yes/No)	Comment
Cadmium	mg/m3	0.06	1st Qrt						Note
Mercury	mg/m3	0.06	1st Qrt						Note
TCDD (equivalent)	ng/m3	0.1	1st Qrt						Note
Type 1 and 2 substances	mg/m3	0.6	1st Qrt						Note
Cadmium	mg/m3	0.06	2nd Qrt						Note
Mercury	mg/m3	0.06	2nd Qrt						Note
TCDD (equivalent)	ng/m3	0.1	2nd Qrt						Note
Total Solid Particles	mg/m3	30	Annual						Note 2
Type 1 and 2 substances	mg/m3	0.6	2nd Qrt						Note
Cadmium	mg/m3	0.06	3rd Qrt						Note
Mercury	mg/m3	0.06	3rd Qrt						Note
TCDD (equivalent)	ng/m3	0.1	3rd Qrt						Note
Type 1 and 2 substances	mg/m3	0.6	3rd Qrt						Note
Cadmium	mg/m3	0.06	4th Qrt						Note
Mercury	mg/m3	0.1	4th Qrt						Note
TCDD (equivalent)	ng/m3	0.1	4th Qrt						Note
Type 1 and 2 substances	mg/m3	0.6	4th Qrt						Note

ND- No Data
N/A- Not Applicable

Note: Quarterly when non-standard fuels are being burnt in the Power Boiler, and not required at other times

Note 2: Concentration Limit only applicable when non-standard fuel is being burnt in the Power Boiler

VP9-10-10.5-FM-007 **Summary of Continuous Emissions Monitoring Data - Lime Kiln A**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26
Monitoring Location No: 4
Description: Discharge duct downstream of Lime Kiln A prior to junction with Stack 1
Monitoring Type: Continuous
Environment Protection Licence: 10232
Reporting Period: July 2026 to June 2027
Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Reporting Level	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Carbon monoxide (CO)	mg/m3	N/A	100.00	4.49	8038.76	750.22	N/A	
		Moisture	%	N/A	100.00	0.00	34.89	28.45	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	9.91	340.18	172.76	N/A	
		Opacity	%	N/A	100.00	0.01	87.77	8.50	N/A	
		Oxygen (O2)	%	N/A	100.00	0.00	19.62	2.72	N/A	
		Temperature	°C	N/A	100.00	226.44	301.35	268.48	N/A	
August	14-Sep	Carbon monoxide (CO)	mg/m3	N/A	100.00	4.49	4941.57	472.10	N/A	
		Moisture	%	N/A	100.00	0.00	35.16	29.17	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	5.52	372.17	194.94	N/A	
		Opacity	%	N/A	100.00	0.00	51.46	7.66	N/A	
		Oxygen (O2)	%	N/A	100.00	0.00	21.17	2.75	N/A	
		Temperature	°C	N/A	100.00	226.44	301.35	266.32	N/A	
September	14-Oct	Carbon monoxide (CO)	mg/m3	N/A	100.00	4.49	7839.89	491.63	N/A	
		Moisture	%	N/A	100.00	0.00	33.75	29.22	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	2.93	323.79	174.20	N/A	
		Opacity	%	N/A	100.00	0.00	59.49	7.54	N/A	
		Oxygen (O2)	%	N/A	100.00	0.50	20.18	2.71	N/A	
		Temperature	°C	N/A	100.00	226.44	301.35	266.45	N/A	

VP9-10-10.5-FM-008 **Summary of Periodic Stack Testing - Lime Kiln A**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 4

Environment Protection Licence: 10232

Description: Discharge duct downstream of Lime Kiln A prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Grab Sample

Sample Type: Air

Pollutant	Unit of measure	Reporting Level	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Compliance(Yes/No)	Comment
Total Solid Particles	mg/m3	N/A	Annual						

ND - No Data
N/A - Not applicable

VP9-10-10.5-FM-025 **Summary of Continuous Emissions Monitoring Data - Lime Kiln B**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26
Monitoring Location No: 21
Environment Protection Licence: 10232
Description: Discharge duct downstream of Lime Kiln B prior to junction with Stack 1
Reporting Period: July 2026 to June 2027
Monitoring Type: Continuous
Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Reporting Level	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Carbon monoxide (CO)	mg/m3	N/A	100.00	0.55	4307.22	268.19	N/A	
		Moisture	%	N/A	100.00	0.00	33.98	24.82	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	0.00	513.83	250.53	N/A	
		Opacity	%	N/A	100.00	0.01	90.64	6.68	N/A	
		Oxygen (O2)	%	N/A	100.00	0.00	21.00	3.38	N/A	
		Temperature	°C	N/A	100.00	65.55	500.00	281.85	N/A	
August	14-Sep	Carbon monoxide (CO)	mg/m3	N/A	100.00	0.60	6000.00	352.88	N/A	
		Moisture	%	N/A	100.00	0.00	32.33	25.34	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	0.00	414.94	229.25	N/A	
		Opacity	%	N/A	100.00	0.01	90.46	4.45	N/A	
		Oxygen (O2)	%	N/A	100.00	0.00	19.98	2.86	N/A	
		Temperature	°C	N/A	100.00	70.40	463.65	276.67	N/A	
September	14-Oct	Carbon monoxide (CO)	mg/m3	N/A	100.00	0.57	4013.10	295.65	N/A	
		Moisture	%	N/A	100.00	0.00	30.97	26.35	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	N/A	100.00	0.00	439.85	266.02	N/A	
		Opacity	%	N/A	100.00	0.01	90.42	3.20	N/A	
		Oxygen (O2)	%	N/A	100.00	0.00	19.87	2.11	N/A	
		Temperature	°C	N/A	100.00	65.20	451.64	292.27	N/A	

VP9-10-10.5-FM-026 **Summary of Periodic Stack Testing - Lime Kiln B**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 21

Environment Protection Licence: 10232

Description: Discharge duct downstream of Lime Kiln B prior to junction with Stack 1

Reporting Period: July 2026 to June 2027

Monitoring Type: Grab Sample

Sample Type: Air

Pollutant	Unit of measure	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Comment
Total Solid Particles	mg/m3	Annual					

General Note: Limits are not applicable to this monitoring point

VP9-10-10.5-FM-027 **Summary of Continuous Emissions Monitoring Data - Stack 2**

VISY
FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 22

Environment Protection Licence: 10232

Description: Exit point from Stack 2 to atmosphere

Reporting Period: July 2026 to June 2027

Monitoring Type: Continuous

Sample Type: Air

Month	Date of publication	Pollutant	Unit of measure	Concentration Limit	Data collected (%)	Lowest value	Highest value	Mean	Compliance (Yes/No)	Comment
July	14-Aug	Flow	Nm3/s	N/A	100.00	0.12	67.10	41.45	N/A	
		Hydrogen chloride	mg/m3	50	100.00	0.04	25.58	0.84	Y	
		Moisture	%	N/A	100.00	0.01	45.00	26.57	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	31.73	152.51	132.87	Y	
		Opacity	%	20	99.83	2.77	97.55	9.73	N	Equipment Issues
		Oxygen (O2)	%	N/A	100.00	3.21	20.94	6.18	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.14	0.84	0.71	Y	
		Temperature	°C	N/A	100.00	107.70	181.62	167.24	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.42	1.86	1.25	Y	
August	14-Sep	Flow	Nm3/s	100	100.00	0.02	66.10	44.46	N/A	
		Hydrogen chloride	mg/m3	50	100.00	0.04	113.41	2.14	Y	Planned Maintenance
		Moisture	%	N/A	100.00	0.01	44.99	20.12	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	13.97	359.27	153.86	Y	
		Opacity	%	20	100.00	7.43	65.08	10.34	N	Equipment Issues
		Oxygen (O2)	%	N/A	100.00	3.56	22.16	6.27	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.02	31.41	0.97	Y	
		Temperature	°C	N/A	100.00	134.47	177.01	166.92	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.32	3.00	1.39	Y	
September	14-Oct	Flow	Nm3/s	N/A	100.00	0.02	53.31	43.41	N/A	
		Hydrogen chloride	mg/m3	50	100.00	0.16	32.40	1.12	Y	
		Moisture	%	N/A	100.00	10.73	30.56	20.34	N/A	
		Nitrogen Oxides (as NO2)	mg/m3	400	100.00	20.86	178.74	160.11	Y	
		Opacity	%	20	100.00	7.91	23.44	10.27	Y	Planned Maintenance
		Oxygen (O2)	%	N/A	100.00	4.17	22.06	6.36	N/A	
		Sulphur dioxide (SO2)	mg/m3	250	100.00	0.25	6.95	1.11	Y	
		Temperature	°C	N/A	100.00	151.51	176.16	165.87	N/A	
		TRS (as H2S)	mg/m3	3.6	100.00	0.16	1.94	1.66	Y	

VP9-10-10.5-FM-028 **Summary of Periodic Stack Testing - Stack 2**

VISY FOR A BETTER WORLD

Latest Publication Date: 14-Oct-26

Monitoring Location No: 22

Environment Protection Licence: 10232

Description: Exit point from Stack 2 to atmosphere

Reporting Period: July 2026 to June 2027

Monitoring Type: Grab Sample

Sample Type: Air

Pollutant	Unit of measure	Concentration Limit	Sampling Freq	Date of Sample	Date of Report	Report No.	Data	Compliance (Yes/No)	Comments
Chlorine	mg/m3	100	Annual						
Sulfuric acid mist & sulfur trioxide (as SO3)	mg/m3	20	Annual						
TCDD (equivalent)	ng/m3	0.1	Annual						
Total Solid Particles	mg/m3	50	1st Qrt	5-Aug-26	01-Sep-26	R020818	8.6	Y	
Total Solid Particles	mg/m3	50	2nd Qrt						
Total Solid Particles	mg/m3	50	3rd Qrt						
Total Solid Particles	mg/m3	50	4th Qrt						
Type 1 and 2 substances	mg/m3	1	Annual						

ND- No Data

N/A- Not Applicable