



Air Monitoring Data Report

The attached table summarises the results of emissions testing carried out on the Visy Gas Fired Boilers combined Discharge Stack for the 2018/19 Reporting Period.

Site: Visy Paper Pty Ltd, Smithfield NSW Licence No: 4100

Date of Test: 18 June 2020 Tester: Ektimo Pty Ltd

Report No: R009395 Report Date: 3 July 2020

Table 1: Summary of Average Emission Test Results (Report No. R009395)

Pollutant	Unit of measure	Concentration limit	Result	Complianc
Nitrogen dioxide	mg/m³	250*	5.6	Yes
Nitric oxide	mg/m³	250*	83	Yes
Oxygen	%	N/A	4.5	N/A
Temperature	°C	N/A	111	N/A
Velocity	m/s	N/A	9	N/A
Volumetric flow rate	m³/s	N/A	17	N/A
Dry gas density	kg/m³	N/A	1.33	N/A
Moisture	%	N/A	15	N/A
Molecular weight stack gases	g/gmol	N/A	29.8	N/A

All results comply with the Environmental Protection Licence emission limits.

Verified by: Date: 29/06/2021

Ben Casauria

Visy National Environment Manager