

**Main Stack 1**

Monitoring Location No: 1  
 Monitoring Type: Continuous  
 Sample Type: Air  
 Description: Exit point from Stack 1 to atmosphere

Opacity		Period: 6 Minutes	Limit: 20.00 %			
Start Time	End Time	Cause	Operational State	Explanation	Max Reading	
01/07/21 13:06	01/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.64	
02/07/21 13:06	02/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.75	
03/07/21 13:06	03/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.92	
04/07/21 13:06	04/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.44	
05/07/21 13:06	05/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.02	
06/07/21 13:06	06/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.90	
07/07/21 13:06	07/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.14	
08/07/21 13:06	08/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.23	
13/07/21 13:06	13/07/21 13:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	30.99	
14/07/21 13:00	14/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.67	
15/07/21 13:00	15/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	20.89	
16/07/21 13:00	16/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.64	
17/07/21 13:00	17/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.90	
18/07/21 13:00	18/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.30	
19/07/21 13:00	19/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.47	
20/07/21 13:00	20/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.84	
21/07/21 13:00	21/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	21.65	
22/07/21 13:00	22/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	22.22	

23/07/21 13:00	23/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.68
24/07/21 13:00	24/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.60
25/07/21 13:00	25/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	24.13
26/07/21 13:00	26/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.52
27/07/21 12:00	27/07/21 12:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.98
27/07/21 13:00	27/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.96
29/07/21 13:00	29/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	28.24
30/07/21 13:00	30/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.81
31/07/21 13:00	31/07/21 13:06	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	23.11

## Main Stack 2

**Monitoring Location No:** 22  
**Monitoring Type:** Continuous  
**Sample Type:** Air  
**Description:** Exit point from Stack 2 to atmosphere

Opacity						Period: 6 Minutes	Limit: 20.00 %
Start Time	End Time	Cause	Operational State	Explanation	Max Reading		
26/07/21 09:24	26/07/21 09:36	Instrument Error	Normal (Steady State)	Main stack opacity checked and calibrated by maintenance	23.13		

Authorised By:

**Uday Bhagwat**  
 Pulp Mill Manager

*Uday Bhagwat*  
9-8-21

**Johan Stoltz**  
 General Manager

*Johan Stoltz*