

Visy Pulp and Paper Tumut CEMS - Exceedance Report

22/12/2022

Reporting Period: 1/11/2022 - 1/12/2022 Environment Protection Licence No: 10232

Main Stack 1

Monitoring Location No: 1
Monitoring Type: Continuous
Sample Type: Air
Description: Exit point from Stack 1 to atmosphere

Sulphur Dioxide (SO2)		Period: 60 Minutes	Limit: 250.00 mg/Nm3			
Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
07/11/22 15:00	07/11/22 17:00	Power Boiler EP	Burning NCG/Stripper Gases in Power Boiler	Gasses to Power Boiler due to SAACKE working on burner Compliance issues	Compliance issues resolved and gasses diverted back to Recovery boiler A	365.75
07/11/22 17:00	07/11/22 19:00	Power Boiler EP	Burning NCG/Stripper Gases in Power Boiler	Gasses to Power Boiler due to SAACKE working on burner Compliance issues	Compliance issues resolved and gasses diverted back to Recovery boiler A	373.98

Power Boiler

Monitoring Location No: 3
Monitoring Type: Continuous
Sample Type: Air
Description: Discharge duct downstream of Power Boiler prior to junction with Stack 1

Carbon Monoxide (CO)		Period: 60 Minutes	Limit: 140.00 mg/Nm3			
Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading

28/11/22 16:00	28/11/22 17:00	Power Boiler	Normal (Steady State)	Boiler not set up correctly.	Working on getting set up in line with it should be to improve combustion in bed.	147.86
29/11/22 02:00	29/11/22 03:00	Power Boiler	Normal (Steady State)	Boiler not set up correctly.	Working on getting set up in line with it should be to improve combustion in bed.	171.19

Main Stack 2

Monitoring Location No: 22

Monitoring Type Continuous

Sample Type: Air

Description: Exit point from Stack 2 to atmosphere

Opacity Period: 6 Minutes Limit: 20.00 %						
Start Time	End Time	Cause	Operational State	Explanation	Corrective Action	Max Reading
01/11/22 16:12	01/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	23.49
02/11/22 16:12	02/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	24.01
03/11/22 16:12	03/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	25.57
04/11/22 16:12	04/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	25.89
05/11/22 16:12	05/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.90
06/11/22 16:12	06/11/22 16:18	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	22.86
11/11/22 16:06	11/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	21.30
13/11/22 16:06	13/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	20.33
14/11/22 16:06	14/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	20.22
15/11/22 16:06	15/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	22.60
16/11/22 16:06	16/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	24.05
17/11/22 16:06	17/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.05
18/11/22 16:06	18/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	24.45
19/11/22 16:06	19/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	25.01
20/11/22 16:06	20/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.49
21/11/22 16:06	21/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.02

22/11/22 16:06	22/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	None Required	25.71
23/11/22 16:06	23/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	24.39
24/11/22 16:06	24/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	N/A	25.40
25/11/22 16:06	25/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	24.84
26/11/22 01:36	26/11/22 01:42	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	21.43
26/11/22 16:06	26/11/22 16:12	Auto Zero Span Verification	Normal (Steady State)	Auto Calibration	n/a	23.02

Authorised By:

Uday Bhagwat
Pulp Mill Manager

Johan Stoltz
General Manager



